



DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY
AFFAIRS (PERA)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99
www.miamidade.gov/pera

GAF Material Corporation
1361 Alps Road
Wayne, NJ 07470

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF Mineral Guard® Residential Roll Roofing

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 11-0603.01
Expiration Date: 01/26/17
Approval Date: 01/26/12
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Asphalt/Fiberglass

SCOPE:

This acceptance is for **GAF Mineral Guard® Residential Roll Roofing**, as manufactured by GAF Materials Corporation, as described in this Notice of Acceptance, for use with approved prepared roof assemblies wherever a ASTM D3909 roof membrane is specified and installed with prescribed approved adhesives, fasteners and fastener densities, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

PRODUCTS DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Mineral Guard® Residential Roll Roofing	39.375" x 32.58'	ASTM D 3909	Asphalt coated, glass fiber mat roll roofing surfaced with mineral granules.

MANUFACTURING LOCATION:

1. Savannah, GA

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies, LLC	GAF-295-02-01	ASTM D3909	03/18/11

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.



NOA No.: 11-0603.01
Expiration Date: 01/26/17
Approval Date: 01/26/12
Page 2 of 3

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Mineral Guard® Residential Roll Roofing is designed for roofs having a minimum slope of 2:12.
3. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code. Mineral Guard® Residential Roll Roofing shall be installed in strict compliance with applicable Building Codes and Manufacturers' specifications and guidelines.
4. Mineral Guard® Residential Roll Roofing may be used with any approved roof covering Notice of Acceptance listing Mineral Guard® Residential Roll Roofing as a component part of an assembly in the Notice of Acceptance. If Mineral Guard® Residential Roll Roofing is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
5. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code

END OF THIS ACCEPTANCE

